

		GOVERNMENT OF TELANGANA STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT RENEWAL of NO OBJECTION CERTIFICATE			
Ack. No.:	1456854002018				
NOC:	0001452/RENEWAL/Ranga Reddy/2018				
NOC TYPE:	RENEWAL*				
Valid Upto:	04-10-2023				
Applicant Details:	R.Pradeep Reddy, Sy No.37, Shantivanam,Karmanghat,Saroor Nagar Mandal, R R Dist.				
Building for which NOC issued:	Pallavi Aware School,Sy No.37, Shantivanam,Karmanghat,Saroor Nagar Mandal, R R Dist.				
Concessions in Setbacks Given in Lieu of Land Surrendered in Road Widening:				No	
Plot Area (Sq. Mtrs):	2788.00	Height (Metres):	6.00		
Open Spaces	North: (F) 2.00	South: 6.00	East: 6.00	West: 6.0	
No. One Ground + 1 Floors	Occupancy Type:		EDUCATIONAL B		
Total Built-up Area (Sq.Mtrs):	2788.00	Staircases:	No. of Staircases Required/Proposed:	2	
Fees Paid (₹):	30668		Aggregate Width Required/Proposed (Metres):	1.50	
Fighting Installations Provided as per Table 23, Part-IV of NBC, 2005:					
Fire Extinguisher:	16	First Aid Hose Reel:	4	Wet Riser:	0
Down Comer:	2	Yard Hydrant:	4	Automatic Sprinkler System:	0
Manually Operated Electronic Fire Alarm Systems:	4	Terrace Tank (Litres):	10000		
Automatic Detection and Alarm System:	0	Underground Static Water Storage Tank (Litres):	20000		
Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm ² at Terrace Level	Type		Quantity		(Capacity in Litres/min)
	Electrical		0		0
	Diesel		0		0
	Jockey		0		0
Fire Pump at the Terrace Tank Level with Minimum Pressure of 2.0 kg/cm ²	(Capacity in Litres/min)				
	900 LPM				
"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"					
*For details and conditions of Renewal No Objection Certificate for Occupancy, refer overleaf".					


DIRECTOR
PALLAVI AWARE SCHOOL


PRINCIPAL
PALLAVI AWARE SCHOOL



GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT NO
OBJECTION CERTIFICATE



The Renewal No Objection Certificate for Occupancy is issued subject to following conditions:

-On the basis of the recommendations of the building inspection committee, this Renewal No Objection Certificate for Occupancy is issued.

-Any person violating the conditions of a No Objection Certificate shall be liable to be proceeded against under the provisions of Fire Service Act, 1999.

- The Owner/Occupier may please note that, the department will conduct surprise inspections to verify the satisfactory working condition of the fire safety systems. During the inspection, if any violation of No Objection Certificate for Occupancy conditions/non-functioning of fire safety systems is noticed, prosecution will be launched on the Owner/Occupier as per the provisions of Fire Service Act, 1999.

- It is the responsibility of the builder/management to apply for Renewal No Objection Certificate for Occupancy duly remitting the user charges as per G.O.Ms.No.71, (Home Prisons-A) Dep., dated: 01-04-2010, two months before expiry of this No Objection Certificate.

f) The floor wise built-up areas of the building are as follows:

Floor Type	Build Up Area
Ground	1394.00
1st Floor	1394.00
Total	2788.00

R. Act

DIRECTOR
PALLAVI AWARE SCHOOL

Sudeshna

PRINCIPAL
PALLAVI AWARE SCHOOL